



Date : 12-09-2020

To,

The Principal

Shiv Nadar School

Faridabad , Haryana

Respected Ma'am/Sir,

The test reports for the Water samples collected from the campus of Shiv Nadar School Faridabad , Haryana are enclosed with this letter. The table below contains the details of the samples collected and the summary of the test results.

S.No.	Item	Place	BCMS Test Slip No	Sample Collected Date	Result
1	Drinking Water	North Block -1 Admission office	SYS0618	28-08-2020	Sample Ok
2	Drinking Water	North Block -1 Corbet (Fourth Floor)	SYS0619	28-08-2020	Sample Ok

Thanking You.

Authorised Signatory,

A handwritten signature in blue ink, appearing to be "M. Singh", is written over the "Authorised Signatory" text.

Blue Circle Medi Services Pvt. Ltd

Encl. 1- The Scan Copy of Test Report from Test.

Blue Circle Medi Services Pvt. Ltd.

J-32, Sarita vihar, New Delhi-110076, Ph: 011-41402320, [E-mail: info@bluecircle.in](mailto:info@bluecircle.in)

Intertek India Pvt. Ltd. (Food Services)

TC-6434

ISSUED TO

BLUE CIRCLE MEDI SERVICES PVT. LTD.
J-33, Sarita Vihar,
New Delhi-76

TEST REPORT

Doc. No. IFSG/RE/QU/005

LAB REFERENCE No. : IFS-200828031

Issue Date : 31/08/2020

Your Ref : TRF

Dated : 28/08/2020

ULR No. : TC643420000006046F

Product Group: Water

Page 1 of 2

Sample Registration Date : 28/08/2020
Analysis starting Date : 28/08/2020
Name of the Product : RO Drinking Water
Quantity Received : 2ltr in glass bottle + 1ltr in plastic bottle
Sample Details : Sample Code: SYS0618, Location: North Block -1 Admission office (Ground Floor)
Sampling done by : Sample collect by Intertek
Tests Required : Chemical and Biological Test
SAMPLE TESTED AS RECEIVED
Analysis Completion Date : 31/08/2020
Reporting code: FS/CR/AT;

TEST RESULTS

Sr. No	Test Parameters	Units of Measurement	Result	Specification IS:10500-2012	Limit of detection	Method of testing
Chemical Parameters						
1.	Colour, true colour units	Hazen	<1.0	Max 5	1.0	IS:3025 (P-4)
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	107.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	6.60	6.5- 8.5	2.0	IS:3025 (P-11)
7.	Total Hardness (as CaCO ₃)	mg/l	25.74	Max 200	1.0	IS:3025 (P-21)
8.	Nitrate (as NO ₃)	mg/l	3.35	Max 45.0	0.5	APHA 23 rd edition



Paliavi
(Authorized Signatory)
PALIAVI
Sr. Analyst

Intertek India Pvt. Ltd. (Food Services)

ISSUED TO

BLUE CIRCLE MEDI SERVICES PVT. LTD.
J-33, Sarita Vihar,
New Delhi-76

TEST REPORT

Doc. No. IFSG/RE/QU/005

LAB REFERENCE No. : IFS-200828031

Issue Date : 31/08/2020

Your Ref : TRF

Dated : 28/08/2020

ULR No. : TC643420000006046F

Product Group: Water

Page 2 of 2

Sample Registration Date : 28/08/2020
Analysis starting Date : 28/08/2020
Name of the Product : RO Drinking Water
Quantity Received : 2ltr in glass bottle + 1ltr in plastic bottle
Sample Details : Sample Code: SYS0618, Location: North Block -1 Admission office (Ground Floor)
Sampling done by : Sample collect by Intertek
Tests Required : Chemical and Biological Test
SAMPLE TESTED AS RECEIVED
Analysis Completion Date : 31/08/2020
Reporting code: FS/CR/AT;

TEST RESULTS

Sr. No	Test Parameters	Units of Measurement	Result	Specification IS:10500-2012	Limit of detection	Method of testing
Biological Parameters						
1.	<i>E.coli</i>	Per 100ml	Absent	Present/Absent	Present/ Absent	IS:15185:2016
2.	Coliform	Per 100ml	Absent	Present/Absent	Present/ Absent	IS:15185:2016
3.	Standard plate count *	cfu/ml	<1	-	≥1.0	IS: 1622:1981 (Reaffirmed 2009)

Note 1: The above results pertain only to the sample tested and applicable parameter.

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Remarks2: - * Not in specification of IS:10500:2012

*****END OF TEST REPORT*****



(Authorized Signatory)

SACHIN TOMAR
Sr. Microbiologist

Intertek India Pvt. Ltd. (Food Services)

ISSUED TO

BLUE CIRCLE MEDI SERVICES PVT. LTD.
J-33, Sarita Vihar,
New Delhi-76

TEST REPORT

Doc. No. IFSG/RE/QU/005

LAB REFERENCE No. : IFS-200828032

Issue Date : 31/08/2020

Your Ref : TRF

Dated : 28/08/2020

ULR No. : TC643420000006047F

p

Product Group: Water

Page 1 of 2

Sample Registration Date : 28/08/2020
Analysis starting Date : 28/08/2020
Name of the Product : RO Drinking Water
Quantity Received : 2ltr in glass bottle + 1ltr in plastic bottle
Sample Details : Sample Code: SYS0619, Location: North Block -1 Corbel (fourth Floor)
Sampling done by : Sample collect by Intertek
Tests Required : Chemical and Biological Test
SAMPLE TESTED AS RECEIVED
Analysis Completion Date : 31/08/2020
Reporting code: FS/CR/AT;

TEST RESULTS

Sr. No	Test Parameters	Units of Measurement	Result	Specification IS:10500-2012	Limit of detection	Method of testing
Chemical Parameters						
1.	Colour, true colour units	Hazen	<1.0	Max 5	1.0	IS:3025 (P-4)
2.	Odour	-	Agreeable	Agreeable	-	IS:3025 (P-5)
3.	Taste	-	Agreeable	Agreeable	-	IS:3025 (P-8)
4.	Turbidity	NTU	<1.0	Max 1.0	1.0	IS:3025 (P-10)
5.	Total Dissolved solids	mg/l	111.0	Max 500	1.0	IS:3025 (P-16)
6.	pH	-	6.62	6.5- 8.5	2.0	IS:3025 (P-11)
7.	Total Hardness (as CaCO ₃)	mg/l	25.74	Max 200	1.0	IS:3025 (P-21)
8.	Nitrate (as NO ₃)	mg/l	3.62	Max 45.0	0.5	APHA 23 rd edition

TC-6434
Intertek India Pvt. Ltd. (Food Services)

ISSUED TO

BLUE CIRCLE MEDI SERVICES PVT. LTD.
J-33, Sarita Vihar,
New Delhi-76

TEST REPORT

Doc. No. IFSG/RE/QU/005

LAB REFERENCE No. : IFS-200828032

Issue Date : 31/08/2020

Your Ref : TRF

Dated : 28/08/2020

ULR No. : TC643420000006047F

p

Product Group: Water

Page 2 of 2

Sample Registration Date : 28/08/2020
Analysis starting Date : 28/08/2020
Name of the Product : RO Drinking Water
Quantity Received : 2ltr in glass bottle + 1ltr in plastic bottle
Sample Details : Sample Code: SYS0619, Location: North Block -1 Corbelt (fourth Floor)
Sampling done by : Sample collect by Intertek
Tests Required : Chemical and Biological Test
SAMPLE TESTED AS RECEIVED
Analysis Completion Date : 31/08/2020
Reporting code: FS/CR/AT;

TEST RESULTS

Sr. No	Test Parameters	Units of Measurement	Result	Specification IS:10500-2012	Limit of detection	Method of testing
Biological Parameters						
1.	<i>E.coli</i>	Per 100ml	Absent	Present/Absent	Present/ Absent	IS:15185:2016
2.	Coliform	Per 100ml	Absent	Present/Absent	Present/ Absent	IS:15185:2016
3.	Standard plate count *	cfu/ml	<1	-	≥1.0	IS: 1622:1981 (Reaffirmed 2009)

Note 1: The above results pertain only to the sample tested and applicable parameter.

Remarks1: - The submitted sample complies to 'IS 10500:2012 requirements' wherever mentioned with respect to the above parameters only.

Remarks2: - * Not in specification of IS:10500:2012

*****END OF TEST REPORT*****

Intertek India Private Limited
intertek
(Authorized Signatory)
SACHIN INDMAR
Sr. Microbiologist