

From Assistant Divisional Fire Officer/Fire Station Officer
MC Gurgaon

To M/s KRN Education Pvt Ltd
Phase I, DLF City, Sector 26A, Gurugram

Memo No. FS/2022/2776 dated : 28/10/2022

Subject: Renewal of Fire Safety Certificate 15 mtrs. and Above height from the fire Safety Point of View of the Group B-Educational Building at Phase I, DLF City, Sector 26A, Gurugram of M/s KRN Education Pvt. Ltd. :

Reference to you online No 050262223003168 dated 06/09/2022 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
Primary School	G+Serv+1st to 4th	19.20 Mtr.	956.645 Sq. Mt.
High School	G+Serv+1st to 4th	19.20 Mtr.	4803.20 Sq. Mt.

Basement Level	Basement Area	Remarks
Basement 1	1394.205 Sq. Mt.	Primary School
Basement 1	167.157 Sq. Mt.	High School

Your site for the Renewal of the Fire Safety Certificate has been inspected by the Team of Fire Station Officers, **MC Gurgaon** from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines.

In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection for occupation from the Fire Safety point of view, with the following conditions:-

- 1) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 2) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 4) You are directed to apply for Renewal of Fire Safety Certificate in future before 2 month of expiry of your Fire Safety Certificate.
- 5) The open set back area is not checked at our end as it shall be checked by concerned building department.
- 6) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section 30,31 & 47 of fire & Emergency Services Act 2022.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents/R.W.A. should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 9) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Renewal of Fire Safety Certificate is valid for **Three** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- HR 778



Gulshan Kalra

**PRINCIPAL
SHIV NADAR SCHOOL
DLF PHASE-I, GURGAON**



Digitally signed by GULSHAN
KALRA
Date: 2022.10.28 12:30
Reason: Digital Verification
MC Gurgaon

Exercising the power of Director, Fire Services, Haryana

From Director General
Fire Service, Haryana Panchkula

To M/s KRN Education Pvt Ltd
Plot No E 1110 1111 and 1127 DLF City Phase I Gurugram

Memo No. FS/2022/263 dated : 04/10/2022

Subject : Approval of fire fighting scheme 15 mtrs. and Above from the fire safety point of view for Group B-Educational Building at Additional Junior Block School Block of Shiv Nadar School at Plot No E 1110,1111 and 1127, DLF City Phase I, Gurugram of M/s KRN Education Pvt. Ltd. :

Reference your Transaction Id 050262223003018 dated: 24/08/2022 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Gurgaon Sector-29, .The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

Tower Name	Floor Detail	Terrace Height of Last Livable Floor(In Meters)	Ground Coverage
Junior School Block	G to 03	17.90 Mtr.	987.118 Sq. Mtrs.
Tower Name	Basement Level	Basement Area	Basement Remarks
	Basement- 01	1014.939 Sq. Mtr.	-

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Five Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

Remarks:- Application Updated



Deputy Director (Technical)-I,
for Director General, Fire
Service, Haryana

Panchkula

Exercising the power of Director, Fire Services, Haryana

PRINCIPAL
SHIV NADAR SCHOOL
DLF PHASE-I, GURGAON



Digitally signed by GULSHAN
KALRA
Date: 2022.10.04 16:27:11 +05:30
Reason: Digital Verification